

# GA Pet Food Partners Wind Turbine

## JRC Consultation Response

### Document Control

Version	Date of Issue	Author(s)
01	October 2025	James Hayward

## 1 Introduction

JRC hold information about critical infrastructure communication links for utilities such as gas and electricity. They do not provide public mapping information, but they do advise whether there is a potential link interference from a wind turbine through a consultation process. This document presents the outcome of the consultation relating to the currently proposed wind turbine.

## 2 Consultation Response

JRC were consulted on the proposed turbine location and they responded with the following on 14<sup>th</sup> Oct 2025:

**“Site Name:** GA Pet Food Partners

**Turbine(s) at NGR:** 346225 419368    **Hub Height:** 111m    **Rotor Radius:** 69m

*This proposal is **\*cleared\*** - **subject to 50m Micrositing** - with respect to radio link infrastructure operated by the local energy networks.*

*JRC analyses proposals for wind farms on behalf of the UK Fuel & Power Industry. This is to assess their potential to interfere with radio systems operated by utility companies in support of their regulatory operational requirements.*

*In the case of this proposed wind energy development, JRC does not foresee any potential problems based on known interference scenarios and the data you have provided. However, if any details of the wind farm change, particularly the disposition or scale of any turbine(s), it will be necessary to re-evaluate the proposal. Please note that due to the large number of adjacent radio links in this vicinity, which have been taken into account, clearance is given specifically for a location within the declared grid reference (quoted above).*

*In making this judgement, JRC has used its best endeavours with the available data, although we recognise that there may be effects which are as yet unknown or inadequately predicted. JRC cannot therefore be held liable if subsequently problems arise that we have not predicted.*

*It should be noted that this clearance pertains only to the date of its issue. As the use of the spectrum is dynamic, the use of the band is changing on an ongoing basis and consequently, you are advised to seek re-coordination prior to submitting a planning application, as this will negate the possibility of an objection being raised at that time as a consequence of any links assigned between your enquiry and the finalisation of your project.”*

## 3 Conclusion

Based on the response above, it is concluded that JRC does not object to the proposed turbine at the present time and does not foresee any potential problems relating to the links JRC manages arising from it. This statement is valid subject to 50m micrositing of the turbine i.e. the turbine may be sited within 50m of the location stated above without objections being raised.